



Underwriters Laboratories Inc.®

May 23, 2000

Texas Energy Savers Company
Mr. Terry Woods
213 Conveyor
P.O. Box 533
Joshua, TX 76058

Our Reference: R19386, 00NK17033

Dear Mr. Woods:

This is in regard to our Project 00NK17033, which was established to Classify your "Tesco SL 1000" metal roofing panel for impact resistance in accordance with UL 2218 and external fire exposure in accordance with UL 790.

Based on previous test experience with steel roof panels of this design and thickness, we have established a Class C fire resistance rating and a Class 4 impact resistance rating without performing any tests.

We have prepared a new Procedure Vol. 1 under file R19386 to cover these Classifications. You should receive the Procedure Volume in the near future.

Since all necessary paperwork has been completed to establish Classification, we are closing Project 00NK17033 with this letter.

Should you have any questions, please feel free to contact the writer.

Very truly yours,

Robert F. Keogh (Ext. 41510)
Associate Project Engineer
Conformity Assessment Services - 3011E-
NBK

Reviewed by:

Douglas C. Miller (Ext. 43262)
Engineering Group Leader
Conformity Assessment Services - 3011E-
NBK